

NC/QC/YPD/2020-21/CH-CB9

Date: 25-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	18-03-21	25-03-21	07	22500	370	16.44	16.22
	002	"	"	"	"	365	16.22	
	003	"	"	"	"	360	16.00	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : 2nd Cross Road(RHS)

Page No. 1/1,

W. S. Sridhar
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CB11

Date: 29-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07 days Compressive Strength).

(Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-405 (Jakkur) Byatarayanapura Sub Division.)

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/mm ²)	Avg. Value
1	001	22-03-21	29-03-21	07	22500	375	16.67	16.74
	002	"	"	"	"	385	17.11	
	003	"	"	"	"	370	16.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Muneshwara Temple Road (RHS)

Page No. 1/1,

29.03.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CB12

Date: 30-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

(Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.)

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	23-03-21	30-03-21	07	22500	370	16.44	16.52
	002	"	"	"	"	380	16.89	
	003	"	"	"	"	365	16.22	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Matru Condiment Road(RHS)

Page No. 1/1,

20.05.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CB13

Date: 01-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07 days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
I	001	25-03-21	01-04-21	07	22500	360	16.00	16.07
	002	"	"	"	"	355	15.78	
	003	"	"	"	"	370	16.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Main Road(RHS)

Page No. 1/1,

28.05.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CB14

Date: 03-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	27-03-21	03-04-21	07	22500	365	16.22	16.15
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	355	15.78	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : 2nd Cross Road(LHS)

Page No. 1/1,

20.05.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



MCQCTPD/2020-21/CH-CB/13

Date: 05-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 7 days Compressive Strength)

(Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05
(Jakkur) Byattarynagar Sub Division.)

Ref: Material testing PMC/20-21.

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BEMP, Bangalore.

Name of the Agency/Contractor*: V.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₃₀

TABLE LI:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/mm ²)	Avg. Value
I	001	29-03-21	05-04-21	07	22500	365	16.22	16.30
	002	-	-	-	-	360	16.00	
	003	-	-	-	-	375	16.67	

The result of the materials tested meets the standards and hence can be used for the work.

Sample Collected Site : Chokkanahalli Layout Main Road(LHS)

Page No. 1/1.

(Signature)
Asst. Executive Engineer
Project Division
Yelahanka Zone
BEMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CB16

Date: 07-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	31-03-21	07-04-21	07	22500	385	17.11	16.59
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	365	16.22	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site :Chokkanahalli Main Road(LHS)

Page No. 1/1,

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CBIA

Date: 23-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

[Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05
(Jakkur) Byatarayanapura Sub Division.]

Ref. Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	23-02-21	23-03-21	28	22500	500	22.22	22.44
	002	"	"	"	"	510	22.67	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Main Road(LHS)

Page No. 1/1,



20-25th
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/YPD/2020-21/CH-CB2A

Date: 26-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	26-02-21	26-03-21	28	22500	525	23.33	22.96
	002	"	"	"	"	515	22.89	
	003	"	"	"	"	510	22.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Matru Condiment Road(RHS)

Page No. 1/1,

W.S.K.
Asst. Executive Engineer
Project Division



NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL: newzen576@gmail.com

NC/QC/YPD/2020-21/CH-CB3A

Date: 30-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm


Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	02-03-21	30-03-21	28	22500	495	22.00	22.22
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Layout Main Road(LHS)

Page No. 1/1,

20-03-21

Asst. Executive Engineer
Project Division



NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL: newzen576@gmail.com

NC/QC/YPD/2020-21/CH-CB4A

Date: 02-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	05-03-21	02-04-21	28	22500	505	22.44	22.59
	002	"	"	"	"	520	23.11	
	003	"	"	"	"	500	22.22	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : 2nd Cross Road(RHS)

Page No. 1/1,

2025/2/20
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP Bangalore - 92



NC/QC/YPD/2020-21/CH-CB5A

Date: 05-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	08-03-21	05-04-21	28	22500	515	22.89	22.81
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	525	23.33	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Muneshwara Temple Road(RHS)

Page No. 1/1,

20.05.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CB6A

Date: 07-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

(Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.)

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	10-03-21	07-04-21	28	22500	520	23.11	22.74
	002	"	"	"	"	510	22.67	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Main Road(LHS)

Page No. 1/1,

W. Sridhar
Asst. Executive Engineer
Project Division
Yelahanka Zone



NC/QC/YPD/2020-21/CH-CB7A

Date: 10-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	13-03-21	10-04-21	28	22500	510	22.67	22.37
	002	"	"	"	"	495	22.00	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Main Road (RHS)

20.04.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NC/QC/YPD/2020-21/CH-CB8A

Date: 14-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	16-03-21	14-04-21	29	22500	495	22.00	22.07
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	490	21.78	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Layout Main Road(LHS)

20.5.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Page No. 1/1,



NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL: newzen576@gmail.com

NC/QC/YPD/2020-21/CH-CB9A

Date: 15-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	18-03-21	15-04-21	28	22500	515	22.89	22.89
	002	"	"	"	"	510	22.67	
	003	"	"	"	"	520	23.11	

The result of the materials tested meets the standards and hence can be used for the work.

Sample Collected Site : 2nd Cross Road(RHS)

22.5.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Page No. 1/1,



NC/QC/YPD/2020-21/CH-CB210A

Date: 17-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	20-03-21	17-04-21	28	22500	515	22.89	22.52
	002	"	"	"	"	495	22.00	
	003	"	"	"	"	510	22.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Main Road(LHS)

29.05.21
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92
Page No. 1/1,



YPD 2020-21/CH-CB11A

TEST REPORT ON CEMENT CONCRETE CUBES:

Date: 19-04-2021

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05
(Jakkur) Byatarayanapura Sub Division.

Ref. Material testing PMC 20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE I.1:

Sl No	Location Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	22-03-21	19-04-21	28	22500	495	22.00	22.2
	002	..	..	..	..	500	22.22	
	003	..	..	..	..	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Muneshwara Temple Road (RHS)

20574
Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Page No. 1/1,



APD/2020-21/CH-CB12A

Date: 20-04-2021

TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05
(Jakkur) Byatarayanapura Sub Division }

Ref: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm


Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	23-03-21	20-04-21	28	22500	505	22.44	22.59
	002	"	"	"	"	520	23.11	
	003	"	"	"	"	500	22.22	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Matru Condiment Road(RHS)

Page No. 1/1,


Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92



NO/QC/YPD/2020-21/CH-CB13A

Date: 22-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05 (Jakkur) Byatarayanapura Sub Division.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	25-03-21	22-04-21	28	22500	515	22.89	22.8
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	525	23.33	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Main Road(RHS)

[Signature]
Asst. Executive Engineer/
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Page No. 1/1,



NEWZEN CONSULTANT BANGALORE, #13, 10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGAR
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL: newzen576@gmail.com

JNANABHARATHI, BANGALORE, #13, 10TH MAIN ROAD AND

NO. QC/SPD/2020-21/CH-CB14A

Date: 24-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength)

Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05
(Jakkur) Byatarayanapura Sub Division }

Ref. Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm


Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	27-03-21	24-04-21	28	22500	510	22.67	22.37
	002	"	"	"	"	495	22.00	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.

Sample Collected Site : 2nd Cross Road(LHS)


Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Page No. 1/1,



REF: YPD 2020-21/CH-C B15A

Date: 26-04-2021

TEST REPORT ON CEMENT CONCRETE CUBES:

For Testing of Concrete Cubes (for 28 days Compressive Strength).

Project: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05
(Jakkur) Byatarayanapura Sub Division;

Ref. Material testing P/MC/20-21.

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency Contractor*: Y. R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE I:

Sl. No.	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	29-03-21	26-04-21	28	22500	495	22.00	22.22
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Layout Main Road(LHS)

Page No. 1/1,

Asst. Executive Engineer
Yelahanka Project Division
BBMP, Bangalore

Signature: [Signature]
Date: 26-04-2021



QC/YPD/2020-21/CH-CB16A

Date: 28-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28 days Compressive Strength).

(Project*: Improvements to roads and Drains at Chokkanahalli Surrounding area in ward no-05
(Jakkur) Byatarayanapura Sub Division.)

Ref. Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Y.R. Sridhar, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/mm ²)	Avg. Value
1	001	31-03-21	28-04-21	28	22500	515	22.89	22.89
	002	"	"	"	"	510	22.67	
	003	"	"	"	"	520	23.11	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Chokkanahalli Main Road(LHS)

Page No. 1/1,

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

